

ANNEXURE-I

PERFORMANCE PARAMETER FOR THE MONTH OF APRIL-MAY-JUNE-2019

Sr. No.	Power Station	PAF (%)			PLF (%)			SHR as Fired (Kcal/Kwh)			Auxi. Consumption (%)			SFC (Kg./Kwh)			Actual Gross Generation (Mus)			Net Generation (Mus)		
		April	May	June	April	May	June	April	May	June	April	May	June	April	May	June	April	May	June	April	May	June
1	Ukai (3-5)	99.33%	99.25%	94.15%	86.44%	84.59%	78.37%	2583	2602	2603	9.23%	9.31%	9.78%	0.31	0.12	1.13	379.63	383.92	344.22	344.61	348.18	310.55
2	Ukai Extn. 6	99.15%	92.36%	85.88%	88.06%	82.29%	68.63%	2398	2355	2370	6.02%	6.23%	6.70%	0.28	0.52	1.24	317.03	306.13	247.05	297.94	287.06	230.51
3	Gandhinagar (3-4)	93.54%	98.92%	99.42%	60.84%	54.46%	36.00%	2554	2562	2579	11.05%	11.22%	12.15%	1.97	1.32	2.08	183.98	170.18	108.87	163.65	151.09	95.65
4	Gandhinagar 5	101.47%	101.55%	100.65%	89.72%	87.61%	86.88%	2498	2511	2532	9.71%	9.70%	9.97%	0.00	0.04	0.00	135.66	136.88	131.37	122.29	123.60	118.27
5	Wanakbori 1-6	80.91%	88.11%	97.08%	65.55%	68.43%	56.72%	2540	2555	2538	9.36%	9.49%	9.77%	1.02	0.39	0.72	594.69	641.47	514.52	538.99	580.59	464.24
6	Wanakbori 7	93.89%	98.95%	101.11%	80.56%	83.82%	71.07%	2461	2464	2462	9.41%	9.37%	9.86%	0.83	0.41	0.77	121.82	130.97	107.46	110.35	118.70	96.87
7	Sikka Extn. (3-4)	98.07%	99.51%	101.10%	72.50%	77.97%	65.34%	2489	2480	2487	9.50%	9.33%	9.58%	1.55	0.50	1.04	261.02	290.06	235.22	236.23	263.01	212.69
8	KLTPS 1-3	44.36%	38.77%	36.09%	46.01%	40.07%	36.78%	3335	3447	3380	15.47%	16.23%	15.66%	13.01	16.48	5.76	71.22	64.10	56.94	60.20	53.70	48.02
9	KLTPS 4	60.32%	33.81%	51.54%	66.74%	37.38%	56.12%	3050	3141	3185	20.58%	25.61%	21.29%	0.01	4.40	2.79	36.04	20.86	30.31	28.62	15.52	23.85
10	BLTPS 1&2	0.00%	0.00%	2.25%	0.00%	0.00%	3.01%	0	0	4117	0.00%	0.00%	0.00%	0.00	0.00	50.25	0.00	0.00	10.83	-2.23	-1.80	5.28
11	Dhuvaran CAPP 1	0.00%	0.00%	0.00%	0.00%	0.00%	0.00%	0	0	0	0.00%	0.00%	0.00%	-	-	-	0.00	0.00	0.00	-0.20	-0.20	-0.16
12	Dhuvaran CAPP 2	3.80%	82.32%	53.72%	3.96%	44.98%	20.37%	2463	1859	2012	25.32%	5.93%	7.48%	-	-	-	3.21	37.63	16.50	2.39	35.40	15.26
13	Dhuvaran CAPP 3	96.74%	74.48%	100.60%	1.08%	9.51%	6.81%	3141	2093	2199	38.87%	6.14%	8.87%	-	-	-	2.92	26.62	18.44	1.79	24.99	16.81
14	Utran Extension	95.86%	98.17%	99.97%	6.65%	13.43%	14.13%	2110	1951	1874	8.18%	5.62%	5.49%	-	-	-	17.94	37.43	38.10	16.47	35.33	36.01
15	Ukai Hydro	94.91%	96.32%	96.32%	7.47%	12.60%	0.00%	-	-	-	1.32%	1.07%	0.00%	-	-	-	16.41	28.60	0.00	16.19	28.30	-0.12
16	Kadana Hydro	93.76%	93.70%	91.26%	3.91%	3.36%	4.31%	-	-	-	0.89%	0.85%	0.78%	-	-	-	6.81	6.05	7.51	6.75	6.00	7.46